



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 8/11/09

Code 52.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Residential Code		Edition First Edition
Section number and title M1601.4.7		Page 1 of 1
Proponent Art Weirauch / OmegaFlex Inc.	Title Mngr. Training and Appl. Engineering	
Address 451 Creamery Way, Eaton, PA, 19341		Phone 610-524-7272
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<u>Exception: CSST which has been tested and shown to be resistant to damage from electrical arcing does not require a 2 inch (49 mm) separation.</u>		
REASON		
<p>This proposed exception recognizes technology that has been successfully introduced to the field. The manufacturers of the technology have shown through testing the resistance ability of the product to withstand transient electrical arcing to levels higher than would be reasonably expected within the structure. 2" separation is not referenced in any standard as being appropriate spacing for reducing the effects of transient electrical arcing.</p> <p><b>Fiscal impact:</b> (submitted for Mr. Weirauch by C. Wagner, no analysis of fiscal impact was submitted by Mr. Weirauch)</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		